



DEPARTMENT OF FORESTRY AND FIRE PROTECTION

OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

SPOT INSPECTION REPORT

LOCATION INFORMATION

Building Name: Storage Yard

Street Address: 2211 East Olympic Blvd

County: Los Angeles

City, State, Zip code: Los Angeles, CA, 90021

Lot Number:

Suite Number:

Floor Number:

Agency: Transportation Dept. (CalTrans) (59900)

SFM File No.: 14-19-81-1495-10001

INSPECTION INFORMATION

Inspection Number : 152387

Inspection Type: Spot Inspection

Inspection Date : 11/21/2023

Inspection Status : Failed

Inspector: Ryan Hernandez

Inspection Hours : 18

Inspector Signature:

Travel Hours : 1

Inspection Comments: On this date, November 21, 2023, an annual fire and life safety inspection for code compliance was conducted by Deputy State Fire Marshal III (Specialist) Jose Duenas and Deputy State Fire Marshal Ryan Hernandez while accompanied by Caltrans Right Away Agent Gary George and property lease holder. The following deficiencies require corrective action:

Discussed With: Rachel Kim

Title: Senior ROW Agent

Accompanied By:

Title: Senior ROW Agent

Rachel Kim

Signed: 12/01/2023

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact Life Safety South at (626) 305-1908 for assistance.



DEPARTMENT OF FORESTRY AND FIRE PROTECTION

OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

SPOT INSPECTION REPORT

Violation # 697721

Description: 510801

Violation Code: Title 24 CFC 2022-102.3

Comments: * Discontinue habitation of the mobile home trailer units under the freeway leased business space. Living onsite is not permitted and shall be discontinued immediately.



Comments:

Violation # 697721

Description: 510801

Violation Code: Title 24 CFC 2022-102.3

Comments: * Discontinue habitation of the mobile home trailer units under the freeway leased business space. Living onsite is not permitted and shall be discontinued immediately.



Comments:

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact Life Safety South at (626) 305-1908 for assistance.



DEPARTMENT OF FORESTRY AND FIRE PROTECTION

OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

SPOT INSPECTION REPORT

Violation # 697721

Description: 510801

Violation Code: Title 24 CFC 2022-102.3

Comments: * Discontinue habitation of the mobile home trailer units under the freeway leased business space. Living onsite is not permitted and shall be discontinued immediately.



Comments:

Violation # 697722

Description: 483

Violation Code: Title 19 Title 19 Current-574

Comments: * Fire extinguishers throughout the storage yard are in need of annual service and are noted to exceed installation requirements.

-Ensure proper mounting heights 4" min. to bottom and no more than 5' to top per Title 19, Division 1, §567.6

Also, 2022 CFC 906.1 and Title 19, Division 1, §3.29



Comments:

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact Life Safety South at (626) 305-1908 for assistance.



DEPARTMENT OF FORESTRY AND FIRE PROTECTION

OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

SPOT INSPECTION REPORT

Violation # 697722

Description: 483

Violation Code: Title 19 Title 19 Current-574

Comments: * Fire extinguishers throughout the storage yard are in need of annual service and are noted to exceed installation requirements.

-Ensure proper mounting heights 4" min. to bottom and no more then 5' to top per Title 19, Division 1, §567.6

Also, 2022 CFC 906.1 and Title 19, Division 1, §3.29



Comments:



DEPARTMENT OF FORESTRY AND FIRE PROTECTION

OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

SPOT INSPECTION REPORT

Violation # 697725

Description: 483

Violation Code: Title 19 Title 19 Current-574

Comments: *Install a minimum of 2A:10B:C fire extinguisher within 50' travel distance to all areas in the fork lift storage yard. It was noted without at the time of inspection.

-Also 906.1 (et. seq.)



Comments:

Violation # 697726

Description: 347

Violation Code: Title 19 Title 19 Current-3.11

Comments: * Provide clear means of egress path to the public way from fork lift storage yard.



Comments:

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact Life Safety South at (626) 305-1908 for assistance.



DEPARTMENT OF FORESTRY AND FIRE PROTECTION

OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

SPOT INSPECTION REPORT

Violation # 698827

Description: 511336

Violation Code: Title 24 CFC 2022-304.1

Comments: *Remove all stored combustibles from underneath the overpass.



Comments:

Violation # 698828

Description: 510885

Violation Code: Title 24 CFC 2022-315.4

Comments: *Remove all stored combustibles from underneath the overpass and within the footprint of the freeway and maintain at least 10' away from adjacent property lines free of combustible storage per 2022 CFC 315.4



Comments:



DEPARTMENT OF FORESTRY AND FIRE PROTECTION

OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

SPOT INSPECTION REPORT

Violation # 698828

Description: 510885

Violation Code: Title 24 CFC 2022-315.4

Comments: *Remove all stored combustibles from underneath the overpass and within the footprint of the freeway and maintain at least 10' away from adjacent property lines free of combustible storage per 2022 CFC 315.4



Comments:

Violation # 698862

Description: 511314

Violation Code: Title 24 CFC 2022-3405.7

Comments: *Remove combustible storage of tires under freeway overpass and structural members.



Comments:



DEPARTMENT OF FORESTRY AND FIRE PROTECTION

OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

SPOT INSPECTION REPORT

Violation # 698862

Description: 511314

Violation Code: Title 24 CFC 2022-3405.7

Comments: *Remove combustible storage of tires under freeway overpass and structural members.



Comments:

Violation # 698862

Description: 511314

Violation Code: Title 24 CFC 2022-3405.7

Comments: *Remove combustible storage of tires under freeway overpass and structural members.



Comments:

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact Life Safety South at (626) 305-1908 for assistance.